

**Annual Drinking Water Quality Report for 2022**  
Salamanca Board of Public Utilities  
225 Wildwood Avenue, Salamanca, New York 14779

City of Salamanca, Public Water Supply ID#NY0400349  
Town of Great Valley WD #1, Public Water Supply ID#NY0412218 (Killbuck)  
Town of Great Valley WD #4, Public Water Supply ID#NY0430052 (Highland Ave.)

## **Introduction**

To comply with State and Federal regulations, the Salamanca Board of Public Utilities will be annually issuing a report describing the quality of your drinking water. The purpose of this report is to raise your understanding of drinking water and awareness of the need to protect our drinking water sources. Last year, your tap water met all State drinking water health standards. We are proud to report that our system did not violate a maximum contaminant level or any other water quality standard. This report provides an overview of last year's water quality. Included are details about where your water comes from, what it contains, and how it compares to State standards.

If you have any questions about this report or concerning your drinking water, please contact Dennis Hensel at (716) 945-3130. We want you to be informed about your drinking water. If you want to learn more, please attend any of our regularly scheduled Salamanca Board of Public Utilities' Monthly Commission Meetings.

## **What are the sources of our water?**

In general, the sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activities. Contaminants that may be present in source water include: microbial contaminants; inorganic contaminants; pesticides and herbicides; organic chemical contaminants; and radioactive contaminants. In order to ensure that tap water is safe to drink, the State and the EPA prescribe regulations which limit the amount of certain contaminants in water provided by public water systems. The State Health Department's and the FDA's regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Our water originates from twelve wells, ranging in depth from 50 feet to more than 80 feet. Eleven wells (WF) are located near Water Street in the center of the City of Salamanca. Another well (GV) is located at the extreme eastern boundary of the City near Great Valley Creek. Since natural filtration of the ground water through an extensive sand and gravel aquifer occurs, only chlorination is required prior to distribution to our customers. The storage tanks, which are located on Newton Run in the City of Salamanca, usually contain between 3.5 and 4 million gallons, which equates to 3.5 to 4 days reserve capacity. During 2022, our system did not experience any water use restrictions.

In 2003, the NYS DOH completed a source water assessment for our water system, based on available information. Possible and actual threats to the drinking waters sources were evaluated. The source water assessment includes a susceptibility rating based on the risk posed by each potential source of contamination and how easily contaminants can move through the subsurface to the wells. The susceptibility rating is an estimate of the potential contamination of the source water. It does not mean that the water delivered to consumers is, or will become contaminated. See section "Are contaminants in our drinking water?" for a list of the contaminants that have been detected. The source water assessments provide resource managers with additional information for protecting source waters into the future.

As was mentioned before, our water is derived from twelve wells. The source water assessment has rated the combined susceptibility to contamination for these wells as high from cations/anions (salts, sulfate), enteric viruses, halogenated solvents, herbicides/pesticides, nitrates, other industrial organics and petroleum products; and medium high from enteric bacteria, metals and protozoa. These ratings for the wells are due to their proximity to industrial activities. While the assessment rates our source as being susceptible to enteric bacteria, please note that our water is disinfected to ensure that the finished water delivered into your home meets New York State's drinking water standards.

A copy of this assessment, including a map of the assessment area, can be obtained by contacting us as noted above.

## **Facts and Figures**

The Salamanca Board of Public Utilities is the supplier of potable water to Customers in the City of Salamanca and in portions of the Townships of Salamanca and Great Valley. There are presently 2,680 service connections, representing an estimated 6,150 potable water users.

The total water produced in 2022 was 408 million gallons. The daily average of water treated and pumped into the distribution system is 1,118,441 gallons per day. Our highest single day was 1,598,000 gallons. The amount of water delivered to customers was nearly 58% of the actual production. The additional quantity of water was used to flush mains, fight fires, for fire training, and leakage. In 2022, water customers were charged \$3.06 per 1,000 gallons of water. Average monthly potable water charges for a family of three should be about \$24.16, or about 81 cents per day. Charges for customers residing in the Townships of Salamanca and Great Valley are presently 175% of those of the City of Salamanca.

### Are contaminants in our drinking water?

As the State regulations require, we routinely test your drinking water for numerous contaminants. These contaminants include coliform bacteria, inorganic compounds, nitrate, lead and copper, volatile organic compounds, total trihalomethanes, haloacetic acids, radiological and synthetic organic compounds. The table presented below depicts which compounds were detected in your drinking water. The State allows us to test for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. All of this data, though representative, may be more than one year old. Also available at the Salamanca Board of Public Utilities' business office, is a list of analytical results for parameters where there were no detections.

It should be noted that all drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline (800) 426-4791 or the Cattaraugus County Health Department at (716) 701-3386. Information is also available from the EPA website: <https://www.epa.gov/dwreginfo/drinking-water-regulations>.

Table of Detected Contaminants							
Contaminant	Violation Yes/No	Date of Sample	Level Detected (Range)	Unit Measurement	MCLG	Regulatory Limit (MCL, TT or AL)	Likely Source of Contamination
<b>Disinfectants</b>							
Chlorine Residual	No	2022	Avg. = .31 (.12 - .55)	mg/l	N/A	MRDL = 4	Water additive used to control microbes.
Total Coliform	No	2/16/22	1 Positive	N/A	N/A	TT = 2 or more positive samples	Naturally present in the environment.
<b>Inorganic Contaminants</b>							
Arsenic	No	2/16/22	High = .6 (ND - .6)	ug/l	N/A	MCL = 10	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes.
Barium	No	2/16/22	High = 157 (77 - 157)	ug/l	2,000	MCL = 2,000	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits.
Copper <sup>1</sup> - City of Salamanca & Town Districts	No	6/9/20	202 (19 - 267)	ug/l	1,300	AL = 1,300	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives.
Lead <sup>2</sup> - City of Salamanca & Town Districts	No	6/9/20	2.2 (ND - 2.7)	ug/l	0	AL = 15	Corrosion of household plumbing systems; erosion of natural deposits.
Nitrate	No	2/16/22	High = 1.22 (.94 - 1.22)	mg/l	10	MCL = 10	Runoff from fertilizer use; leaching from septic tanks, Sewage; erosion of natural deposits.
<b>Disinfection By-Products</b>							
Total Trihalomethanes				ug/l	N/A	MCL = 80	By-product of drinking water disinfection needed to kill harmful organisms. TTHms are formed when source water contains large amounts of organic matter.
- City	No	8/10/22	14				
- G.V. TWD #4	No	8/10/21	1.3				

#### Notes:

1 - The levels presented represent the 90<sup>th</sup> percentile of the 20 sites tested. A percentile is a value on a scale of 100 that indicates the percent of a distribution that is equal to or below it. The 90<sup>th</sup> percentile is equal to or greater than 90% of the copper or lead values detected at your water system. In this case, 20 samples were collected within the City and Town districts and the 90<sup>th</sup> percentile value for copper was the third highest value, 202 ug/l. The action level for copper was not exceeded at any of the sites tested.

2 - The 90<sup>th</sup> percentile values for lead in the City System and the Town Districts combined was 2.2 ug/l. None of the samples exceeded the action level of 15 ug/l for lead.

**Definitions:**

**Action Level (AL):** The concentration of a contaminant, which, if exceeded, triggers treatment or other requirements which a water system must follow.

**Maximum Contaminant Level (MCL):** The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible.

**Maximum Contaminant Level Goal (MCLG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

**Maximum Residual Disinfectant Level (MRDL):** The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

**Maximum Residual Disinfectant Level Goal (MRDLG):** The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contamination.

**Micrograms per liter (ug/l):** Corresponds to one part of liquid in one billion parts of liquid (parts per billion – ppb).

**Milligrams per liter (mg/l):** Corresponds to one part of liquid in one million parts of liquid (parts per million – ppm).

**N/A:** Not applicable.

**Non-Detects (ND):** Laboratory analysis indicates that the constituent is not present.

**What does this information mean?**

As you can see by the table, our system had no violations. We have learned through our testing that some contaminants have been detected; however, these contaminants were detected at values well below the level allowed by the State. Regardless, we are required to provide the following information on lead in drinking water.

Lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The City of Salamanca is responsible for providing high quality drinking water and removing lead pipes, but cannot control the variety of materials used in plumbing components in your home. You share the responsibility for protecting yourself and your family from the lead in your home plumbing. You can take responsibility by identifying and removing lead materials within your home plumbing and take steps to reduce your family’s risk. Before drinking tap water, flush your pipes for several minutes by running your tap, taking a shower, doing laundry or a load of dishes. You can also use a filter certified by an American National Standards Institute accredited certifier to reduce lead in drinking water. If you are concerned about lead in your water and wish to have your water tested, contact (716) 945-3130. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <http://www.epa.gov/safewater/lead>.

**Is our water system meeting other rules that govern operations?**

On August 28, 2019, the CCHD conducted a sanitary survey of our water systems. Two deficiencies were noted and are listed below.

- 1) Individual sample taps for each source at the well field were not available. If necessary, this situation would not allow for “triggered source water monitoring” as required by the US EPA’s Ground Water Rule. However, be advised that in December 2019 we installed taps for half of the well field when the original piping was replaced.
- 2) No standby power is provided at either well house. However, we do have a diesel pump at the Water Street treatment plant that can pump chlorinated water but at a rate lower than the average day demand. Due to available storage this should not create a problem unless power remained off for more than a day or a major fire occurred.

We are presently working with an engineering firm to complete a feasibility study for the necessary capital improvements. Once the study is complete we can apply for grant funding for the improvements.

Also, on 9/21/2022, the Town of Great Valley was issued a Notice of Monitoring Violation from the Cattaraugus County Health Department (CCHD) for failure to collect a water sample for total coliform monitoring, between 10/1/2020 – 12/31/2020, from the Great Valley Town Water District #4. Be advised that the CCHD collects these routine samples. However, due to COVID-19 and their staff’s required participation in that program, they missed collecting the sample. Be advised, even though the County collects our routine bacteriological samples, it doesn’t relieve us of the responsibility of complying with Part 5 of NYS Sanitary Code regarding monitoring and notification requirements.

Although this is not an emergency, as our customers you have a right to know what happened and what we are going to do to correct this situation. Be advised that all bacteriological samples collected in Great Valley Town Water District #4 in 2020 were negative for total coliform.

## **Do I need to take special precautions?**

Although our drinking water met or exceeded state and federal regulations, some people may be more vulnerable to disease causing microorganisms or pathogens in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and some infants can be particularly at risk from infections. These people should seek advice from their health care provider about their drinking water. EPA/DCD guidelines on appropriate means to lessen the risk of infection by Cryptosporidium, Giardia and other microbial pathogens are available from the Safe Drinking Water Hotline (800) 426-4791.

## **Why saving water is a good idea.**

Although our system has an adequate amount of water to meet present and future demands, there are a number of reasons why it is important to conserve water.

- Saving water saves energy and some of the costs associated with both of these necessities of life;
- Saving water reduces the costs of energy required to pump water and the need to construct costly new wells, pumping systems and water towers; and
- Saving water lessens the strain on the water system during a dry spell or drought and helps to avoid severe water use restrictions so that essential firefighting needs are met.

You can play a role in conserving water by becoming conscious of the amount of water your household is using, and by looking for ways to use less whenever you can. It is not hard to conserve water. Conservation tips include:

- Automatic dishwashers use 15 gallons for every cycle, regardless of how many dishes are loaded. So get a run for your money and load it to capacity.
- Turn off the tap when brushing your teeth.
- Check every faucet in your home for leaks. Just a slow drip can waste 15 to 20 gallons a day. Fix it up and you can save almost 6,000 gallons per year.
- Check your toilets for leaks by putting a few drops of food coloring in the tank, watch for a few minutes, to see if the color shows up in the bowl. It is not uncommon to lose up to 100 gallons a day from one of those otherwise invisible toilet leaks. Fix it and you save more than 30,000 gallons a year.
- Use your water meter to detect hidden leaks. Simply turn off all taps and water using appliances. Then check the meter after 15 minutes, if it moved, you have a leak.

## **System Improvements**

The Board of Public Utilities is committed to serving the community by revamping and modernizing the water production and treatment process to take advantage of the most effective and economical technology available. Improvements have recently taken place and more will be undertaken in the near future in response to the changing environment and stricter government regulations.

## **Water System Security**

The Board of Public Utilities would like to remind residents to remain vigilant of any suspicious activity regarding the water distribution system. Please report any suspicious activity to the Board of Public Utilities or the Salamanca Police Department.

## **Closing**

Thank you for allowing us to continue to provide you and your family with quality drinking water this year. We ask that all our customers help us protect our water sources, which are the heart of the community and our way of life. Please call our office if you have questions.